SIEMENS

Data sheet

6ES7511-1TK01-0AB0



SIMATIC S7-1500T, CPU 1511T-1 PN, Central processing unit with Work memory 225 KB for program and 1 MB for data, 1st interface: PROFINET IRT with 2-port switch, 60 ns bit performance, SIMATIC Memory Card required

General information	
Product type designation	CPU 1511T-1 PN
HW functional status	FS04
Firmware version	V2.9
Product function	
I&M data	Yes; I&M0 to I&M3
• Isochronous mode	Yes; Distributed and central; with minimum OB $6x$ cycle of $625~\mu s$ (distributed) and 1 ms (central)
Engineering with	
 STEP 7 TIA Portal configurable/integrated from version 	V17 (FW V2.9) / V14 (FW V2.0) or higher
Configuration control	
via dataset	Yes
Display	
Screen diagonal [cm]	3.45 cm
Control elements	
Number of keys	6
Mode selector switch	1
Supply voltage	
Type of supply voltage	DC
Rated value (DC)	24 V
permissible range, lower limit (DC)	19.2 V
permissible range, upper limit (DC)	28.8 V
Reverse polarity protection	Yes
Mains buffering	
 Mains/voltage failure stored energy time 	5 ms
 Repeat rate, min. 	1/s
Input current	
Current consumption (rated value)	0.7 A
Inrush current, max.	1.9 A; Rated value
l²t	0.02 A ² ·s
Power	
Infeed power to the backplane bus	10 W
Power consumption from the backplane bus (balanced)	5.5 W
Power loss	
Power loss, typ.	5.7 W
Memory	
Number of slots for SIMATIC memory card	1
SIMATIC memory card required	Yes

Modernoon	
Work memory	225 khyta
• integrated (for program)	225 kbyte
• integrated (for data)	1 Mbyte
Load memory	22 Chuta
Plug-in (SIMATIC Memory Card), max. Peakup	32 Gbyte
Backup maintenance-free	Yes
1 11 1 11 11	165
CPU processing times	00.00
for bit operations, typ.	60 ns
for word operations, typ.	72 ns 96 ns
for fixed point arithmetic, typ.	
for floating point arithmetic, typ. CPU-blocks	384 ns
	A 0000 Blacks (OR ER EQ DR) and URTs
Number of elements (total) DB	4 000; Blocks (OB, FB, FC, DB) and UDTs
Number range	1 60 999; subdivided into: number range that can be used by the
• Number range	user: 1 59 999, and number range of DBs created via SFC 86: 60 000 60 999
• Size, max.	1 Mbyte; For DBs with absolute addressing, the max. size is 64 KB
FB	
Number range	0 65 535
• Size, max.	150 kbyte
FC	
Number range	0 65 535
• Size, max.	150 kbyte
ОВ	
• Size, max.	150 kbyte
 Number of free cycle OBs 	100
 Number of time alarm OBs 	20
 Number of delay alarm OBs 	20
 Number of cyclic interrupt OBs 	20; With minimum OB 3x cycle of 500 μs
 Number of process alarm OBs 	50
 Number of DPV1 alarm OBs 	3
 Number of isochronous mode OBs 	2
 Number of technology synchronous alarm OBs 	2
 Number of startup OBs 	100
 Number of asynchronous error OBs 	4
 Number of synchronous error OBs 	2
Number of diagnostic alarm OBs	1
Nesting depth	
per priority class	24
Counters, timers and their retentivity	
S7 counter	
Number	2 048
Retentivity	
— adjustable	Yes
IEC counter	
• Number	Any (only limited by the main memory)
Retentivity	
— adjustable	Yes
S7 times	
• Number	2 048
Retentivity	
— adjustable	Yes
IEC timer	
• Number	Any (only limited by the main memory)
Retentivity	V
— adjustable	Yes
Data areas and their retentivity	
Retentive data area (incl. timers, counters, flags), max.	128 kbyte; In total; available retentive memory for bit memories, timers,

	counters, DBs, and technology data (axes): 88 KB
Extended retentive data area (incl. timers, counters, flags), max.	1 Mbyte; When using PS 6 0W 24/48/60 V DC HF
Flag	
• Size, max.	16 kbyte
Number of clock memories	8; 8 clock memory bit, grouped into one clock memory byte
Data blocks	
 Retentivity adjustable 	Yes
Retentivity preset	No
Local data	
per priority class, max.	64 kbyte; max. 16 KB per block
Address area	
Number of IO modules	1 024; max. number of modules / submodules
I/O address area	
Inputs	32 kbyte; All inputs are in the process image
Outputs	32 kbyte; All outputs are in the process image
per integrated IO subsystem	,,
— Inputs (volume)	8 kbyte
— Outputs (volume)	8 kbyte
per CM/CP	
— Inputs (volume)	8 kbyte
— Outputs (volume)	8 kbyte
Subprocess images	0.103.0
Number of subprocess images, max.	32
·	- 52
Hardware configuration	
Number of distributed IO systems	32; A distributed I/O system is characterized not only by the integration of distributed I/O via PROFINET or PROFIBUS communication modules, but also by the connection of I/O via AS-i master modules or links (e.g. IE/PB-Link)
Number of DP masters	
• Via CM	4; A maximum of 4 CMs/CPs (PROFIBUS, PROFINET, Ethernet) can be inserted in total
Number of IO Controllers	
integrated	1
Via CM	4; A maximum of 4 CMs/CPs (PROFIBUS, PROFINET, Ethernet) can be inserted in total
Rack	
 Modules per rack, max. 	32; CPU + 31 modules
Number of lines, max.	1
PtP CM	
Number of PtP CMs	the number of connectable PtP CMs is only limited by the number of available slots
Fine of day	
Clock	Hardware clock
• Type	
Backup time Deviction per day, may	6 wk; At 40 °C ambient temperature, typically
Deviation per day, max. Operating hours counter.	10 s; Typ.: 2 s
Operating hours counter	40
Number	16
Clock synchronization	V
• supported	Yes
• in AS, master	Yes
• in AS, slave	Yes
on Ethernet via NTP	Yes
nterfaces	
Number of PROFINET interfaces	1
1 11 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	
1 11 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	
1. Interface Interface types	Yes; X1
1. Interface	Yes; X1

Protocols	
• IP protocol	Yes; IPv4
 PROFINET IO Controller 	Yes
 PROFINET IO Device 	Yes
 SIMATIC communication 	Yes
Open IE communication	Yes; Optionally also encrypted
Web server	Yes
Media redundancy	Yes
PROFINET IO Controller	
Services	
— PG/OP communication	Yes
 Isochronous mode 	Yes
 Direct data exchange 	Yes; Requirement: IRT and isochronous mode (MRPD optional)
— IRT	Yes
— PROFlenergy	Yes; per user program
 Prioritized startup 	Yes; Max. 32 PROFINET devices
 Number of connectable IO Devices, max. 	128; In total, up to 256 distributed I/O devices can be connected via AS-i, PROFIBUS or PROFINET
 Of which IO devices with IRT, max. 	64
 Number of connectable IO Devices for RT, max. 	128
— of which in line, max.	128
 Number of IO Devices that can be simultaneously activated/deactivated, max. 	8; in total across all interfaces
 Number of IO Devices per tool, max. 	8
— Updating times	The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data
Update time for IRT	
— for send cycle of 250 μs	250 µs to 4 ms; Note: In the case of IRT with isochronous mode, the
— for send cycle of 500 μs	minimum update time of 625 µs of the isochronous OB is decisive 500 µs to 8 ms; Note: In the case of IRT with isochronous mode, the minimum update time of 625 µs of the isochronous OB is decisive
— for send cycle of 1 ms	1 ms to 16 ms
— for send cycle of 2 ms	2 ms to 32 ms
— for send cycle of 4 ms	4 ms to 64 ms
With IRT and parameterization of "odd" send	Update time = set "odd" send clock (any multiple of 125 μs: 375 μs, 625
cycles	μs 3 875 μs)
Update time for RT	
— for send cycle of 250 μs	250 µs to 128 ms
— for send cycle of 500 μs	500 μs to 256 ms
— for send cycle of 1 ms	1 ms to 512 ms
— for send cycle of 2 ms	2 ms to 512 ms
— for send cycle of 4 ms	4 ms to 512 ms
PROFINET IO Device	
Services	
— PG/OP communication	Yes
— Isochronous mode	No
— IRT	Yes
— PROFlenergy	Yes; per user program
— Shared device	Yes
 Number of IO Controllers with shared device, max. 	4
 activation/deactivation of I-devices 	Yes; per user program
 Asset management record 	Yes; per user program
Interface types	
RJ 45 (Ethernet)	
• 100 Mbps	Yes
Autonegotiation	Yes
Autocrossing	Yes
Industrial Ethernet status LED	Yes
Protocols	

PROFIsafe	No
Number of connections	
 Number of connections, max. 	96; via integrated interfaces of the CPU and connected CPs / CMs
 Number of connections reserved for ES/HMI/web 	10
 Number of connections via integrated interfaces 	64
 Number of S7 routing paths 	16
Redundancy mode	
H-Sync forwarding	Yes
Media redundancy	
Media redundancy	only via 1st interface (X1)
— MRP	Yes; MRP Automanager according to IEC 62439-2 Edition 2.0, MRP
	Manager; MRP Client
 MRP interconnection, supported 	Yes; as MRP ring node according to IEC 62439-2 Edition 3.0
— MRPD	Yes; Requirement: IRT
 Switchover time on line break, typ. 	200 ms; For MRP, bumpless for MRPD
 Number of stations in the ring, max. 	50
SIMATIC communication	
PG/OP communication	Yes; encryption with TLS V1.3 pre-selected
S7 routing	Yes
S7 communication, as server	Yes
S7 communication, as client	Yes
User data per job, max.	See online help (S7 communication, user data size)
Open IE communication	200 Simile Help (OF Communication, door data size)
TCP/IP	Yes
— Data length, max.	64 kbyte
 several passive connections per port, 	Yes
supported	Voo
• ISO-on-TCP (RFC1006)	Yes
— Data length, max.	64 kbyte
• UDP	Yes
— Data length, max.	2 kbyte; 1 472 bytes for UDP broadcast
— UDP multicast	Yes; Max. 5 multicast circuits
• DHCP	Yes
• DNS	Yes
• SNMP	Yes
• DCP	Yes
• LLDP	Yes
Encryption	Yes; Optional
Web server	
• HTTP	Yes; Standard and user pages
• HTTPS	Yes; Standard and user pages
OPC UA	
 Runtime license required 	Yes; "Small" license required
OPC UA Client	Yes
 Application authentication 	Yes
— Security policies	Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256
— User authentication	"anonymous" or by user name & password
 Number of connections, max. 	4
 Number of nodes of the client interfaces, max. 	1 000
 Number of elements for one call of OPC_UA_NodeGetHandleList/OPC_UA_ReadList/0 max. 	300
 Number of elements for one call of OPC_UA_NameSpaceGetIndexList, max. 	20
 Number of elements for one call of OPC_UA_MethodGetHandleList, max. 	100
 Number of simultaneous calls of the client instructions per connection (except OPC_UA_ReadList,OPC_UA_WriteList,OPC_UA_N max. 	1 <i>1</i>
 Number of simultaneous calls of the client instructions 	5

OPC_UA_ReadList,OPC_UA_WriteList and	
OPC_UA_MethodCall, max.	5.000
Number of registerable nodes, max.	5 000
 Number of registerable method calls of OPC UA MethodCall, max. 	100
Number of inputs/outputs when calling	20
OPC_UA_MethodCall, max.	
OPC UA Server	Yes; Data access (read, write, subscribe), method call, custom address space
 Application authentication 	Yes
— Security policies	Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256
 User authentication 	"anonymous" or by user name & password
 — GDS support (certificate management) 	Yes
— Number of sessions, max.	32
 Number of accessible variables, max. 	50 000
 Number of registerable nodes, max. 	10 000
 Number of subscriptions per session, max. 	20
— Sampling interval, min.	100 ms
— Publishing interval, min.	500 ms
 Number of server methods, max. 	20
 Number of inputs/outputs per server method, max. 	20
 Number of monitored items, max. 	1 000; for 1 s sampling interval and 1 s send interval
Number of server interfaces, max.	10 of each "Server interfaces" / "Companion specification" type and 20 of the type "Reference namespace"
 Number of nodes for user-defined server interfaces, max. 	1 000
Alarms and Conditions	Yes
	100
— Number of program alarms— Number of alarms for system diagnostics	50
Further protocols	50
Futitiei protocois	
·	Vac: MODRUS TOP
• MODBUS	Yes; MODBUS TCP
MODBUS Isochronous mode	
MODBUS Isochronous mode Equidistance	Yes; MODBUS TCP Yes
MODBUS Isochronous mode Equidistance S7 message functions	Yes
MODBUS Isochronous mode Equidistance S7 message functions Number of login stations for message functions, max.	Yes 32
MODBUS Isochronous mode Equidistance S7 message functions Number of login stations for message functions, max. Program alarms	Yes 32 Yes
MODBUS Isochronous mode Equidistance S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max.	Yes 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH
MODBUS Isochronous mode Equidistance S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max.	Yes 32 Yes 5 000; Program messages are generated by the "Program_Alarm"
MODBUS Isochronous mode Equidistance S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms	Yes 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500
MODBUS Isochronous mode Equidistance S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms	Yes 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600
MODBUS Isochronous mode Equidistance S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics	Yes 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100
MODBUS Isochronous mode Equidistance S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects	Yes 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600
MODBUS Isochronous mode Equidistance S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions	Yes 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 80
MODBUS Isochronous mode Equidistance S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering)	Yes 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 80 Yes; Parallel online access possible for up to 5 engineering systems
MODBUS Isochronous mode Equidistance S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block	Yes 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 80 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients)
MODBUS Isochronous mode Equidistance S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step	Yes 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 80 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No
MODBUS Isochronous mode Equidistance S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints	Yes 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 80 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients)
MODBUS Isochronous mode Equidistance S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control	Yes 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 80 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8
MODBUS Isochronous mode Equidistance S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control Status/control variable	Yes 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 80 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8
MODBUS Isochronous mode Equidistance S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control Status/control variable Variables	Yes 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 80 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8
MODBUS Isochronous mode Equidistance S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control Status/control variable Variables Number of variables, max.	Yes 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 80 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters
MODBUS Isochronous mode Equidistance S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control Status/control Status/control variable Variables Number of variables, max. — of which status variables, max.	Yes 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 80 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters 200; per job
MODBUS Isochronous mode Equidistance S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control Status/control variable Variables Number of variables, max. — of which status variables, max. — of which control variables, max.	Yes 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 80 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters
MODBUS Isochronous mode Equidistance S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control Status/control Status/control variable Variables Number of variables, max. — of which status variables, max. — of which control variables, max. Forcing	Yes 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 80 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters 200; per job 200; per job
● MODBUS Isochronous mode Equidistance S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms ● Number of program alarms ● Number of alarms for system diagnostics ● Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control ● Status/control variable ● Variables ● Number of variables, max. — of which status variables, max. — of which control variables, max. Forcing ● Forcing	Yes 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 80 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters 200; per job 200; per job
MODBUS Isochronous mode Equidistance S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control Status/control Status/control variable Variables Number of variables, max. of which status variables, max. of which control variables, max. Forcing Forcing Forcing Forcing, variables	Yes 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 80 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters 200; per job 200; per job Yes Peripheral inputs/outputs
MODBUS Isochronous mode Equidistance S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control Status/control Status/control variable Variables Number of variables, max. — of which status variables, max. — of which control variables, max. Forcing Forcing Forcing, variables, max.	Yes 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 80 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters 200; per job 200; per job
MODBUS Isochronous mode Equidistance S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control Status/control Status/control variable Variables Number of variables, max. of which status variables, max. of which control variables, max. Forcing Forcing Forcing Forcing, variables	Yes 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 80 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters 200; per job 200; per job Yes Peripheral inputs/outputs

Number of entries, may	1 000
 Number of entries, max. — of which powerfail-proof 	500
Traces	500
Number of configurable Traces	4; Up to 512 KB of data per trace are possible
Interrupts/diagnostics/status information	4, op to 012 NB of data per trace are possible
Diagnostics indication LED	
RUN/STOP LED	Yes
• ERROR LED	Yes
MAINT LED	Yes
Connection display LINK TX/RX	Yes
Supported technology objects	
Motion Control	Yes; Note: The number of technology objects affects the cycle time of
Modell Control	the PLC program; selection guide via the TIA Selection Tool
 Number of available Motion Control resources for technology objects 	800
 Required Motion Control resources 	
per speed-controlled axis	40
per positioning axis	80
per synchronous axis	160
— per external encoder	80
— per output cam	20
— per cam track	160
— per probe	40
Number of available Extended Motion Control resources for technology objects	40
Required Extended Motion Control resources	
— per cam (1 000 points and 50 segments)	2
— per cam (10 000 points and 50 segments)	20
— for each set of kinematics	30
— Per leading axis proxy	3
Positioning axis	5
 — Number of positioning axes at motion control cycle of 4 ms (typical value) — Number of positioning axes at motion control 	5 10
cycle of 8 ms (typical value)	10
Controller	
PID_Compact	Yes; Universal PID controller with integrated optimization
PID_3Step	Yes; PID controller with integrated optimization for valves
PID-Temp	Yes; PID controller with integrated optimization for temperature
Counting and measuring	
High-speed counter	Yes
Ambient conditions	
Ambient temperature during operation	
horizontal installation, min.	0 °C
horizontal installation, max.	60 °C; Display: 50 °C, at an operating temperature of typically 50 °C, the display is switched off
vertical installation, min.	0 °C
 vertical installation, max. 	40 °C; Display: 40 °C, at an operating temperature of typically 40 °C, the display is switched off
Ambient temperature during storage/transportation	and place of the control of the cont
• min.	-40 °C
• max.	70 °C
Altitude during operation relating to sea level	
 Installation altitude above sea level, max. 	5 000 m; Restrictions for installation altitudes > 2 000 m, see manual
configuration / header	
configuration / programming / header	
Programming language	
— LAD	Yes
— FBD	Yes
— STL	Yes
— SCL	Yes

— GRAPH	Yes
Know-how protection	
 User program protection/password protection 	Yes
 Copy protection 	Yes
Block protection	Yes
Access protection	
 protection of confidential configuration data 	Yes
 Password for display 	Yes
 Protection level: Write protection 	Yes
 Protection level: Read/write protection 	Yes
Protection level: Complete protection	Yes
programming / cycle time monitoring / header	
 lower limit 	adjustable minimum cycle time
• upper limit	adjustable maximum cycle time
Dimensions	
Width	35 mm
_ Height	147 mm
Depth	129 mm
Weights	
Weight, approx.	430 g

last modified:

11/3/2021